Appendix C SRPI.21.014 File: D02-20023

From: Habibur Rahman

To: Hoodad Abootalebi

Cc: Hubert Ng; Pat Hosein

Subject: RE: *Request for Comments* City File # D02-20023 - 19 Pearson Avenue - Xiuka Zhu

Date: Monday, November 30, 2020 4:39:13 PM

Attachments: <u>image001.jpg</u>

image002.jpg

Hi Hoodad.

Transportation would accept a minimum of 23m ROW for a collector road and a 1.5 metre widening is required along the frontage of 19 Pearson Avenue. The required daylighting triangle at the Pearson/Westwood intersection is 4.5mX4.5m.

Regards, Habibur

Habibur **R**ahman Traffic Analyst Extension 5447

From: Hoodad Abootalebi < hoodad.abootalebi@richmondhill.ca>

Sent: Monday, November 30, 2020 11:24 AM

To: Habibur Rahman <habibur.rahman@richmondhill.ca>

Subject: RE: *Request for Comments* City File # D02-20023 - 19 Pearson Avenue - Xiuka Zhu

The following attachments have been sent to you using Mail Express®:

19 PEARSON - ADJACENT PROPERTY PLAN.pdf (1.6 MB)

19 PEARSON - ARBORIST REPORT.pdf (782.2 KB)

19 PEARSON - CITY SUBMISSION REQUIREMENTS.pdf (1.2 MB)

19 PEARSON - CONSOLIDATED DEVELOPMENT APPLICATION FORMS.pdf (548.4 KB)

19 PEARSON - DEVELOPMENT APPLICATION SUMMARY.pdf (193.6 KB)

19 PEARSON - LOT GRADING PLAN (CORNER LOT).pdf (699.8 KB)

19 PEARSON - LOT GRADING PLAN (INTERNAL LOT).pdf (679.9 KB)

19 PEARSON - PLAN of SURVEY.pdf (214.0 KB)

19 PEARSON - PLANNING JUSTIFICATION REPORT-DRAFT ZONING BY-LAW.pdf (1.8 MB)

19 PEARSON - PRELIMINARY ELEVATIONS PLAN.pdf (206.8 KB)

19 PEARSON - SITE-CONCEPT PLAN.pdf (206.5 KB)

19 PEARSON - SUBMISSION COVER LETTER.pdf (69.1 KB)

19 PEARSON - TREE REMOVAL and PLANTING PLAN (LOT 1).pdf (504.1 KB)

19 PEARSON - TREE REMOVAL-PROTECTION and PLANTING PLAN (LOT 2).pdf (584.2 KB)

Circulation Details.doc (35.5 KB)

Click the links above or visit the <u>pick-up portal</u> for batch retrieval or to reply with your own attachments. These links will expire in 2 week(s).